

10-day Water Outage

due to an Earthquake in 2016




6-month Water Rationing

The rainfall from August 2014 to March 2015 was at an all-time-low since records began in 1947.



Tainan Cty


in Feb. 2016






Water Usage Issues in Southern Taiwan

Water Use in Southern Taiwan




Current Situation of Water Supply







1. NO raw water backup pipelines




Drought Event


(22nd Apr. 2015)








2. Water Supply Issues in Kaohsiung City





3. Pressure of water supply in Nanhua Reservoir


Capacity is less, but load is heavier.





4. Only one route can supply water.

Water won't be able to be sent out during an emergency.





After the project reaches completion, we can...




- ✓ Increase a backup pipeline to support
- ✓ Connect water resources of main reservoirs
- ✓ Dispatch water resources more flexibly
- ✓ Lower water shortage risks





Main Content of the Project





- **Starts at**Penstock of Power plant
- Connects to
 - 1. Nanhua Purification Plant
 - 2. Nanhua/Gaoping Pipeline
- Total length
 25 km
- Max discharge capacity 800,000 CMD



Period & Expenditure

✓ Period: 2019~2024



Planning & Investigation


Basic Design

Detail Design & Construction

Management

✓ Total Expenditure: 12 billion NTD (0.4 billion USD)

Year	2019	2020	2021	2022	2023	2024	Total
Expenditure (*million NTD)	39	534	967	2,251	3,346	4,325	12,000





Intake Segment of the Pipeline



Plan view of Intake Segment










1 No.1 diversion tunnel


- It connects with the hydropower plant penstock.
- Water has gone through the tunnel after generating electricity.

2 No.2 diversion tunnel


- No water has gone through it since the reservoir started working.
- It provides an access to PRO operating room.



The Intake Segment of the interconnecting Pipeline



3D View of Intake Segment






Energy Dissipation Segment of the Pipeline




Excess Energy





Energy Dissipation Design









1st Step:

Vertical stilling well & fixed cone valve



2nd Step:

Baffle-drop Structure






3 Crucial Issues

in the Left Abutment

Issue 1: Safety of Tunnel Excavation

✓ Impact of the new tunnel excavation in the left abutment on the safety of existing tunnels





Factor of Safety

"Underground Excavations" (by Hoek & Brown)

$$D_h = 2.5 \times (a_1 + a_2) \times F.S.$$

a₁=6m; D_h: Horizontal distance

 a_2 =2.25m; a_1 : radius of #2 diversion tunnel

 $D_h=30m$ a_2 : radius of new tunnel

F.S.: factor of safety

□ F.S. = **1.45**OK!

i.e. The excavation of new tunnel won't influence the safety of existing tunnels.

Issue 2: Water Hammer on Power Plant

✓ Water hammer effect on the power plant system due to closure of the new intake pipeline.

✓ 4 Simulation Scenarios:

Scenario A: Current condition, total load rejection

Scenario B: Total load rejection, new pipeline in operation

Scenario C: Power plant in operation, new pipeline closure

Scenario D: Total load rejection, new pipeline closure

(load rejection:電廠跳機, new pipeline closure:本聯通管關閉)

Simulation Results





Fig. Analyzed Maximum Pressure Envelops due to Load Rejection and Closure of Flow Control Valve

☐ Impact on the existing power plant system from closure of new intake pipeline can be neglected.



Issue 3: Influence on ventilation

✓ Influence on ventilation required for PRO






Evaluate the lack of ventilation caused by the reduction in section area.




Issue 3: Influence on ventilation

Ventilation Tunnel to PRO



Calculation Results



	Cross-Sectional Area				
	Current Condition	After Construction			
Sec. A	74 m ²	O.K			
Sec. B	109.51 m ²	88.75 m ²			
Sec. of Ventilation tunnel to PRO	22.39 m ²				

It is judged that the project won't have obvious effects on ventilation required for PRO.

Short Conclusion



intake segment of this pipeline~

Issue 1

Impact of New Tunnel Excavation

Issue 2

Water Hammer effect on Power Plant

Issue 3

Influence on ventilation required for PRO

