

表10 海水淡化廠營運概況
Table 10. State of Desalination Plant Operation
民國九十一年(2002)

廠名 Production Plant	實際營運時間 (日) Actual Operation Time(days)	海水取水量(萬噸) Seawater Intake Capacity(10,000 metric ton)	實際造水量(萬噸) Actual Water Release(10,000 metric ton)	濃鹽水排放量(萬噸) Outlet Capacity of Dense Saline water(10,000 metric ton)
馬公海淡廠 Makung Seawater Desalination Plant	365	627.00	239.00	388.00
南竿海淡廠 Nankan Seawater Desalination Plant (I)	183	8.64	2.25	6.39
尖山發電廠 Gin-shan Power Station	306	70.50	9.18	61.32
核三發電廠(一號機) The 3rd Nuclear Power Station (I)	185	44.99	20.57	24.42
核三發電廠(二號機) The 3rd Nuclear Power Station (II)	215	52.41	23.97	28.44

資料來源：經濟部水利署公務統計報表。

附 註：馬公海淡廠及南竿海淡廠『濃鹽水排放量』含公用系統清洗水。

Data Source:Statistical Reports, WRA, MOEA.